



GOVERNMENT OF WEST BENGAL
OFFICE OF THE DEPUTY DIRECTOR SOUTH ZONE
WEST BENGAL FIRE & EMERGENCY SERVICES
CITY CENTRE, DURGAPUR-16

Memo No.Dy.DFS/ KMP/FS/844 /2013

Dated: 9/12/13

From

Deputy Director
South zone

To

The The Secretary Of
Gitanjali Teacher Training College
Vill+P.O-Choa, Dist-Murshidabad
P.S-Haripur



Sub-Fire & life safety recommendation in favour of Gitanjali Teacher Training College, over Plot No. R.S/L.R.9053, Kh.No-4743, J.L.No-59, Mauza-Choa, Murshidabad.

Ref: Your application dated 25/10/2013.

There is to reference to your letter dated 25/10/2013 regarding Fire Safety recommendation/Fir Safety Certificate in connection with Provisional N.O.C for the (G+2) existing educational building shed in favour of Gitanjali Teacher Training College, over Plot No. R.S/L.R.9053, Kh No.4743, J.L.No.59, Mauza-Choa, Murshidabad.


The plan drawing submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of Plan with recommendation, this office is issuing Fire Safety recommendation in favour of the aforesaid building subject to the compliance of the following Fire Safety Measure.


Enclosed; Recommendation.


Deputy Director
South Zone
West Bengal Fire & Emergency Services
6/11/13
Deputy Director (S. Z.)
W. B. F. E. S.

RECOMMENDATIONS


1. No Addition & Renovation in respect of building constructional side & storage side must be made without prior permission of Deputy Director (South Zone), W.B.F & E.S.
2. Means of Escape must keep free from any obstruction.
3. One stair Emergency Exit must be provided for evacuation in case of Emergency.
4. Safe distance must be maintained for car parking at least 20'.
5. Different types of combustibles materials not to be stored inside of the building.
6. No cooking arrangements allow inside the building only process food allowed.
7. Good Housekeeping must always be maintained.
8. All electrical line & equipments should be checked be Regd. Electrician.
9. M.C.P has to be provided.
10. Booster pump have to be connected with alternative power supply.
11. Down come with 100mm have to be provided.
12. Sprinkler in each corridor have to be provided.
13. Always kept full overhead tank and adequate quantity of must kept for fighting purposes.
14. No gas stove/kerosene stove allowed inside the building.
15. If necessary for kitchen to be placed or provided at least 10' apart from the building.
16. Fix up A.B.C 5kg. Portable extinguisher in each floor.
17. One no of Hose Reel with nozzle to be connected at all floor covering floor area.
18. 2" pipe to be connecting from over head to ground floor 2way Fire service in left for facilities sufficient of water in case of Emergency.
19. Always in active in work to your submersible pump, 2Generator Emergency purposes.
20. All staff to be trained for primary fire fighting with the help of portable Extinguisher & Hose Reel.
21. 4 nos. of fire buckets install at ground floor.
22. Route Diagram chart pasted corner of stair cases.
23. Another stair cases Recommendation for emergency purposes.
24. Always kept free all stair cases.
25. 24 hrs. Engaged one person for look after all equipments & Gear and awareness of fire.
26. Any dispute arises in the land the Fire Service not to be responsible for that.
27. This fire safety Recommendations valid for one year from the date of issue and prior information is required for further extension the period.
28. N.B: Any violation of the above safety recommendations, if found, the provisional N.O.C will be treated as cancelled.


Deputy Director (S. Z.)
W. B. F. E. S.



GOVERNMENT OF WEST BENGAL
DEPARTMENT OF THE FIRE SERVICE
(For Building of all Categories)
13-D, Mirza Ghalib Street, Kolkata—16

Memo No. A.P.O/5/123/13.



Dated, the 29/8/13

To

The Secretary of Gitanjali Teachers Training College.
Mill + P.O. Choa, Dist. Murshidabad.
P.S. Harihar Para.

(G+2) Existing Educational building

Sub : Demand Notice under Section-11C of WBFS Act, 1950 as amended for
issue of Provisional N.O.C. for the Premises No. plat no. R.S/L.R. 9053.
kh. no - 4743, J.L. NO - 59.
mausa, choa, Murshidabad.

Dear Sir / Madam,

With reference to the building application submitted in respect to the above proposed this is to inform you that the building permit along with the sanctioned plan will be issued subject to the payment of fee amount Rs. 5000/-

You are hereby requested to remit the above amount immediately from the date of receipt of the notice.

Total Floor Area (in Sq. Mtr.)	:	
Ground Floor Area (in Sq. Mtr.)	:	843 Sqm.
Primari use Group	:	
Total additional Floor Area	:	
Abutting Road width	:	
Amount in words	:	Five Thousand only.

Mode of Payment :-

Treasury Challan drawn in favour of—"0070-Other Administrative Service-00-109-Fire Protection & Control-001-Fees under the West Bengal Fire Service Act-13-Licence Fees" (A/Cs Code : 0070-109-001-13) to be deposited in Treasury / RBI.

The Treasury / RBI Challan Receipt (in Original) should be submitted in this Office on receipt of the same Provisional N.O.C. will be issued.

Yours faithfully,

[Signature]
29/8/13
Deputy Director (S. Z.)
W. B. F. E. S.